

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
4/1/2022	8.3	Y
4/2/2022	8.3	Y
4/3/2022	8.3	Y
4/4/2022	8.3	Y
4/5/2022	8.3	Y
4/6/2022	8.4	Y
4/7/2022	8.4	Y
4/8/2022	8.3	Y
4/9/2022	8.3	Y
4/10/2022	8.3	Y
4/11/2022	8.4	Y
4/12/2022	8.3	Y
4/13/2022	8.3	Y
4/14/2022	8.3	Y
4/15/2022	8.3	Y
4/16/2022	8.3	Y
4/17/2022	8.3	Y
4/18/2022	8.3	Y
4/19/2022	8.3	Y
4/20/2022	8.3	Y
4/21/2022	8.3	Y
4/22/2022	8.3	Y
4/23/2022	8.3	Y
4/24/2022	8.3	Y
4/25/2022	8.4	Y
4/26/2022	8.4	Y
4/27/2022	8.4	Y
4/28/2022	8.4	Y
4/29/2022	8.5	Y
4/30/2022	8.4	Y

County: Multnomah Agency: Region 1

Entry Point

EP-A

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: **April 2022**

Sampling Period: **January to June 2022**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:

pH 8.0

Print Name: Anna Vosa, P.E.

Signature: 

Date: 5/9/22

Total No's: 0