

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
6/1/2022	8.6	Y
6/2/2022	8.6	Y
6/3/2022	8.6	Y
6/4/2022	8.6	Y
6/5/2022	8.6	Y
6/6/2022	8.5	Y
6/7/2022	8.5	Y
6/8/2022	8.5	Y
6/9/2022	8.5	Y
6/10/2022	8.6	Y
6/11/2022	8.5	Y
6/12/2022	8.6	Y
6/13/2022	8.5	Y
6/14/2022	8.6	Y
6/15/2022	8.5	Y
6/16/2022	8.5	Y
6/17/2022	8.6	Y
6/18/2022	8.6	Y
6/19/2022	8.6	Y
6/20/2022	8.5	Y
6/21/2022	8.6	Y
6/22/2022	8.6	Y
6/23/2022	8.6	Y
6/24/2022	8.6	Y
6/25/2022	8.7	Y
6/26/2022	8.6	Y
6/27/2022	8.6	Y
6/28/2022	8.6	Y
6/29/2022	8.7	Y
6/30/2022	8.6	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **June 2022**

Sampling Period: **January to June 2022**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 7/7/22

Total No's: 0