

## Lead & Copper Rule Corrosion Control

Date	Average pH	Average Alkalinity	Minimums Met? (Y/N)
3/1/2024	8.9		Y
3/2/2024	8.9		Y
3/3/2024	8.9		Y
3/4/2024	8.9		Y
3/5/2024	8.9	29	Y
3/6/2024	8.9		Y
3/7/2024	8.8		Y
3/8/2024	8.8		Y
3/9/2024	8.9		Y
3/10/2024	8.9		Y
3/11/2024	8.9		Y
3/12/2024	8.9	29	Y
3/13/2024	8.9		Y
3/14/2024	9.0		Y
3/15/2024	8.9		Y
3/16/2024	8.9		Y
3/17/2024	8.9		Y
3/18/2024	8.9		Y
3/19/2024	8.9	29	Y
3/20/2024	8.9		Y
3/21/2024	8.9		Y
3/22/2024	8.9		Y
3/23/2024	8.9		Y
3/24/2024	8.9		Y
3/25/2024	8.9		Y
3/26/2024	8.8	28	Y
3/27/2024	8.9		Y
3/28/2024	8.9		Y
3/29/2024	8.8		Y
3/30/2024	8.8		Y
3/31/2024	8.9		Y

**Total N's: 0**

County: Multnomah Agency: Region 1

**Entry Point  
EP-A  
(Bull Run)**

**PWS ID: OR 4100657  
Portland Bureau of Water Works**

Month: **March 2024**

Sampling Period: **January to June 2024**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

**Minimum EP-A Water Quality  
Parameters (WQPs) as set by State:**

pH:	8.6 pH units
Alkalinity:	26 mg/L as CaCO <sub>3</sub>

**Print Name:** Anna Vosa, P.E.

**Signature:** 

**Date:** 4/7/24