

Lead & Copper Rule Corrosion Control

| Date | Average pH | Average Alkalinity | Minimums Met? (Y/N) |
|-----------|------------|--------------------|---------------------|
| 4/1/2024 | 8.8 | | Y |
| 4/2/2024 | 8.9 | 28 | Y |
| 4/3/2024 | 8.9 | | Y |
| 4/4/2024 | 8.9 | | Y |
| 4/5/2024 | 8.9 | | Y |
| 4/6/2024 | 8.9 | | Y |
| 4/7/2024 | 8.9 | | Y |
| 4/8/2024 | 8.9 | | Y |
| 4/9/2024 | 8.8 | 28 | Y |
| 4/10/2024 | 8.9 | | Y |
| 4/11/2024 | 8.9 | | Y |
| 4/12/2024 | 8.8 | | Y |
| 4/13/2024 | 8.8 | | Y |
| 4/14/2024 | 8.9 | | Y |
| 4/15/2024 | 8.9 | | Y |
| 4/16/2024 | 8.9 | 29 | Y |
| 4/17/2024 | 8.9 | | Y |
| 4/18/2024 | 8.8 | | Y |
| 4/19/2024 | 8.9 | | Y |
| 4/20/2024 | 8.9 | | Y |
| 4/21/2024 | 8.9 | | Y |
| 4/22/2024 | 8.9 | | Y |
| 4/23/2024 | 8.9 | 28 | Y |
| 4/24/2024 | 8.9 | | Y |
| 4/25/2024 | 8.9 | | Y |
| 4/26/2024 | 8.9 | | Y |
| 4/27/2024 | 8.9 | | Y |
| 4/28/2024 | 8.8 | | Y |
| 4/29/2024 | 8.8 | | Y |
| 4/30/2024 | 8.9 | 28 | Y |

Total N's: 0

County: Multnomah Agency: Region 1

Entry Point

**EP-A
(Bull Run)**

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: **April 2024**

Sampling Period: **January to June 2024**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

Minimum EP-A Water Quality

Parameters (WQPs) as set by State:

| | |
|-------------|------------------------------|
| pH: | 8.6 pH units |
| Alkalinity: | 26 mg/L as CaCO ₃ |

Print Name: Anna Vosa, P.E.

Signature: 

Date: 5/7/24