

Lead & Copper Rule Corrosion Control

Date	Average pH	Average Alkalinity	Minimums Met? (Y/N)
5/1/2024	8.9		Y
5/2/2024	8.9		Y
5/3/2024	8.9		Y
5/4/2024	8.9		Y
5/5/2024	9.0		Y
5/6/2024	8.9		Y
5/7/2024	8.9	28	Y
5/8/2024	8.9		Y
5/9/2024	8.9		Y
5/10/2024	8.9		Y
5/11/2024	8.9		Y
5/12/2024	8.9		Y
5/13/2024	8.9		Y
5/14/2024	8.9	28	Y
5/15/2024	8.9		Y
5/16/2024	8.9		Y
5/17/2024	8.9		Y
5/18/2024	8.9		Y
5/19/2024	8.9		Y
5/20/2024	8.9		Y
5/21/2024	8.9	29	Y
5/22/2024	8.9		Y
5/23/2024	8.9		Y
5/24/2024	8.9		Y
5/25/2024	8.9		Y
5/26/2024	8.9		Y
5/27/2024	8.9		Y
5/28/2024	8.9	29	Y
5/29/2024	8.9		Y
5/30/2024	8.9		Y
5/31/2024	8.9		Y

Total N's: 0

County: Multnomah Agency: Region 1

Entry Point

EP-A

(Bull Run)

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: **May 2024**

Sampling Period: **January to June 2024**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

Minimum EP-A Water Quality Parameters (WQPs) as set by State:

pH:	8.6 pH units
Alkalinity:	26 mg/L as CaCO ₃

Print Name: Anna Vosa, P.E.

Signature: 

Date: 6/5/2024