

Lead & Copper Rule Corrosion Control

Date	Average pH	Average Alkalinity	Minimums Met? (Y/N)
6/1/2024	8.9		Y
6/2/2024	8.9		Y
6/3/2024	8.9		Y
6/4/2024	8.9	29	Y
6/5/2024	8.8		Y
6/6/2024	8.9		Y
6/7/2024	8.9		Y
6/8/2024	8.9		Y
6/9/2024	8.9		Y
6/10/2024	8.9		Y
6/11/2024	8.9	29	Y
6/12/2024	8.9		Y
6/13/2024	8.9		Y
6/14/2024	8.9		Y
6/15/2024	8.9		Y
6/16/2024	8.9		Y
6/17/2024	8.9		Y
6/18/2024	8.9	31	Y
6/19/2024	8.9		Y
6/20/2024	8.9		Y
6/21/2024	8.9		Y
6/22/2024	8.9		Y
6/23/2024	8.9		Y
6/24/2024	8.7		Y
6/25/2024	8.9	30	Y
6/26/2024	8.9		Y
6/27/2024	8.9		Y
6/28/2024	9.0		Y
6/29/2024	9.0		Y
6/30/2024	8.9		Y

Total N's: 0

County: Multnomah Agency: Region 1

**Entry Point
EP-A
(Bull Run)**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **June 2024**

Sampling Period: **January to June 2024**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

**Minimum EP-A Water Quality
Parameters (WQPs) as set by State:**

pH:	8.6 pH units
Alkalinity:	26 mg/L as CaCO ₃

Print Name: Anna Vosa, P.E.

Signature: 

Date: 7/9/24