

Lead & Copper Rule Corrosion Control

Date	Average pH	Average Alkalinity	Minimums Met? (Y/N)
11/1/2024	8.8		Y
11/2/2024	8.8		Y
11/3/2024	8.8		Y
11/4/2024	8.8		Y
11/5/2024	8.8	30	Y
11/6/2024	8.9		Y
11/7/2024	8.9		Y
11/8/2024	8.9		Y
11/9/2024	8.9		Y
11/10/2024	8.8		Y
11/11/2024	8.9		Y
11/12/2024	8.9	31	Y
11/13/2024	8.9		Y
11/14/2024	8.9		Y
11/15/2024	8.9		Y
11/16/2024	9.0		Y
11/17/2024	9.0		Y
11/18/2024	8.9		Y
11/19/2024	8.9	29	Y
11/20/2024	8.9		Y
11/21/2024	8.9		Y
11/22/2024	8.9		Y
11/23/2024	8.9		Y
11/24/2024	8.9		Y
11/25/2024	8.9		Y
11/26/2024	8.9	30	Y
11/27/2024	8.9		Y
11/28/2024	8.9		Y
11/29/2024	8.9		Y
11/30/2024	8.9		Y

Total N's: 0

County: Multnomah Agency: Region 1

Entry Point

**EP-A
(Bull Run)**

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: **November 2024**

Sampling Period: **July to December 2024**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this
6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

Minimum EP-A Water Quality

Parameters (WQPs) as set by State:

pH:	8.6 pH units
Alkalinity:	26 mg/L as CaCO ₃

Print Name: Anna Vosa, P.E.

Signature: 

Date: 12/6/24