

Lead & Copper Rule Corrosion Control

Date	Average pH	Average Alkalinity	Minimums Met? (Y/N)
1/1/2025	8.9		Y
1/2/2025	8.9		Y
1/3/2025	8.9		Y
1/4/2025	8.9		Y
1/5/2025	8.9		Y
1/6/2025	8.9		Y
1/7/2025	8.8	31	Y
1/8/2025	8.9		Y
1/9/2025	8.9		Y
1/10/2025	8.9		Y
1/11/2025	8.9		Y
1/12/2025	8.9		Y
1/13/2025	8.8		Y
1/14/2025	8.9	31	Y
1/15/2025	8.9		Y
1/16/2025	8.9		Y
1/17/2025	8.9	32	Y
1/18/2025	8.8		Y
1/19/2025	8.8		Y
1/20/2025	8.8		Y
1/21/2025	8.9	31	Y
1/22/2025	8.9		Y
1/23/2025	8.9		Y
1/24/2025	8.9		Y
1/25/2025	8.9		Y
1/26/2025	8.9		Y
1/27/2025	8.9		Y
1/28/2025	8.9	31	Y
1/29/2025	8.9		Y
1/30/2025	8.9		Y
1/31/2025	8.9		Y

Total N's: 0

County: Multnomah Agency: Region 1

Entry Point

**EP-A
(Bull Run)**

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: **January 2025**

Sampling Period: **January to June 2025**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

Minimum EP-A Water Quality

Parameters (WQPs) as set by State:

pH:	8.6 pH units
Alkalinity:	26 mg/L as CaCO ₃

Print Name: Anna Vosa, P.E.

Signature: 

Date: 2/5/25