

Lead & Copper Rule Corrosion Control

Date	Average pH	Average Alkalinity	Minimums Met? (Y/N)
2/1/2025	8.8		Y
2/2/2025	8.8		Y
2/3/2025	8.9		Y
2/4/2025	8.9	30	Y
2/5/2025	8.9		Y
2/6/2025	8.9		Y
2/7/2025	8.9		Y
2/8/2025	8.9		Y
2/9/2025	8.9		Y
2/10/2025	8.9		Y
2/11/2025	8.9	31	Y
2/12/2025	8.9		Y
2/13/2025	8.9		Y
2/14/2025	8.9		Y
2/15/2025	8.9		Y
2/16/2025	8.9		Y
2/17/2025	8.9		Y
2/18/2025	8.8	31	Y
2/19/2025	8.9		Y
2/20/2025	8.9		Y
2/21/2025	8.9		Y
2/22/2025	8.9		Y
2/23/2025	8.9		Y
2/24/2025	8.9		Y
2/25/2025	8.9	28	Y
2/26/2025	8.9		Y
2/27/2025	8.9		Y
2/28/2025	8.9		Y

Total N's: **0**

County: Multnomah Agency: Region 1

Entry Point

EP-A
(Bull Run)

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: **February 2025**

Sampling Period: **January to June 2025**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this
6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

Minimum EP-A Water Quality

Parameters (WQPs) as set by State:

pH	8.6 pH units
Alkalinity	26 mg/L as CaCO ₃

Print Name: Anna Vosa, P.E.

Signature: 

Date: 3/6/25