

Lead & Copper Rule Corrosion Control

Date	Average pH	Average Alkalinity	Minimums Met? (Y/N)
4/1/2025	8.9	29	Y
4/2/2025	8.9		Y
4/3/2025	8.9		Y
4/4/2025	9.0		Y
4/5/2025	9.0		Y
4/6/2025	8.9		Y
4/7/2025	8.9		Y
4/8/2025	8.9	29	Y
4/9/2025	9.0		Y
4/10/2025	9.0		Y
4/11/2025	8.8		Y
4/12/2025	8.9		Y
4/13/2025	8.9		Y
4/14/2025	8.9		Y
4/15/2025	8.9	29	Y
4/16/2025	8.9		Y
4/17/2025	8.9		Y
4/18/2025	8.9		Y
4/19/2025	8.9		Y
4/20/2025	8.9		Y
4/21/2025	8.9		Y
4/22/2025	8.9	30	Y
4/23/2025	8.9		Y
4/24/2025	8.8		Y
4/25/2025	8.9		Y
4/26/2025	8.9		Y
4/27/2025	8.9		Y
4/28/2025	8.8		Y
4/29/2025	8.8	29	Y
4/30/2025	8.9		Y

Total N's: 0

County: Multnomah Agency: Region 1

Entry Point

**EP-A
(Bull Run)**

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: **April 2025**

Sampling Period: **January to June 2025**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

Minimum EP-A Water Quality

Parameters (WQPs) as set by State:

pH	8.6 pH units
Alkalinity	26 mg/L as CaCO ₃

Print Name: Anna Vosa, P.E.

Signature: 

Date: 5/7/25