

Lead & Copper Rule Corrosion Control

Date	Average pH	Average Alkalinity	Minimums Met? (Y/N)
12/1/2025	8.9		Y
12/2/2025	8.8	29	Y
12/3/2025	8.9		Y
12/4/2025	8.9		Y
12/5/2025	8.8		Y
12/6/2025	8.8		Y
12/7/2025	8.9		Y
12/8/2025	8.9		Y
12/9/2025	9.0	32	Y
12/10/2025	9.1		Y
12/11/2025	9.1		Y
12/12/2025	9.1		Y
12/13/2025	9.1		Y
12/14/2025	9.1		Y
12/15/2025	9.0		Y
12/16/2025	9.1	32	Y
12/17/2025	9.1		Y
12/18/2025	9.1		Y
12/19/2025	9.1		Y
12/20/2025			
12/21/2025	Bull Run		
12/22/2025	Not in Use		
12/23/2025			
12/24/2025			
12/25/2025			
12/26/2025	9.1		Y
12/27/2025	9.1		Y
12/28/2025	9.1		Y
12/29/2025	9.1		Y
12/30/2025	9.1	33	Y
12/31/2025	9.1		Y

Total N's: 0

County: Multnomah Agency: Region 1

**Entry Point
EP-A
(Bull Run)**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **December 2025**

Sampling Period: **July to December 2025**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

**Minimum EP-A Water Quality
Parameters (WQPs) as set by State:**

pH	8.6 pH units
Alkalinity	26 mg/L as CaCO3

Print Name: Anna Vosa, P.E.

Signature: 

Date: 1/8/26