

Lead & Copper Rule Corrosion Control

Date	Average pH	Average Alkalinity	Minimums Met? (Y/N)
1/1/2026	9.1		Y
1/2/2026	9.1		Y
1/3/2026	9.1		Y
1/4/2026	9.1		Y
1/5/2026	9.1		Y
1/6/2026	9.0	34	Y
1/7/2026	9.1		Y
1/8/2026	9.0		Y
1/9/2026	9.1		Y
1/10/2026	9.1		Y
1/11/2026	9.1		Y
1/12/2026	9.0		Y
1/13/2026	9.0	28	Y
1/14/2026	9.0		Y
1/15/2026	9.0		Y
1/16/2026	9.0		Y
1/17/2026	9.1		Y
1/18/2026	9.1		Y
1/19/2026	9.1		Y
1/20/2026	9.1	30	Y
1/21/2026	9.0		Y
1/22/2026	9.0		Y
1/23/2026	9.1		Y
1/24/2026	9.1		Y
1/25/2026	9.1		Y
1/26/2026	9.1		Y
1/27/2026	9.1	30	Y
1/28/2026	9.1		Y
1/29/2026	9.1		Y
1/30/2026	9.0		Y
1/31/2026	9.0		Y

Total N's: 0

County: Multnomah Agency: Region 1

Entry Point

**EP-A
(Bull Run)**

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: **January 2026**

Sampling Period: **January to June 2026**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

Minimum EP-A Water Quality

Parameters (WQPs) as set by State:

pH	8.6 pH units
Alkalinity	26 mg/L as CaCO ₃

Print Name: Anna Vosa, P.E.

Signature: 

Date: 2/9/26