

Lead & Copper Rule Corrosion Control

Date	Average pH	Average Alkalinity	Minimums Met? (Y/N)
3/1/2026	8.8		Y
3/2/2026	8.8		Y
3/3/2026	8.8	29	Y
3/4/2026	8.8		Y
3/5/2026	8.8		Y
3/6/2026	8.8		Y
3/7/2026	8.8		Y
3/8/2026	8.8		Y
3/9/2026	8.9		Y
3/10/2026	8.9	28	Y
3/11/2026	8.9		Y
3/12/2026	8.8		Y
3/13/2026	8.9		Y
3/14/2026	8.9		Y
3/15/2026	8.9		Y
3/16/2026	8.9		Y
3/17/2026	8.8	28	Y
3/18/2026	9.0		Y
3/19/2026	9.0		Y
3/20/2026	9.0		Y
3/21/2026	9.0		Y
3/22/2026	9.1		Y
3/23/2026	9.0		Y
3/24/2026	9.1	28	Y
3/25/2026	9.0		Y
3/26/2026	9.0		Y
3/27/2026	9.0		Y
3/28/2026	9.0		Y
3/29/2026	9.0		Y
3/30/2026	9.0		Y
3/31/2026	9.0	29	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A
(Bull Run)**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **March 2026**

Sampling Period: **January to June 2026**

Total days minimum WQPs not met during this month, EP-A only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

**Minimum EP-A Water Quality
Parameters (WQPs) as set by State:**

pH	8.6 pH units
Alkalinity	26 mg/L as CaCO ₃

Print Name: Anna Vosa, P.E.

Signature: 

Date: 4/8/26

Total N's: 0