

# Lead & Copper Rule Corrosion Control

Date	Average pH	Minimums Met? (Y / N)
4/1/2024		
4/2/2024		
4/3/2024		
4/4/2024		
4/5/2024		
4/6/2024		
4/7/2024		
4/8/2024		
4/9/2024		
4/10/2024		
4/11/2024		
4/12/2024		
4/13/2024	<b>Groundwater</b>	
4/14/2024	<b>Not in Use</b>	
4/15/2024		
4/16/2024		
4/17/2024		
4/18/2024		
4/19/2024		
4/20/2024		
4/21/2024		
4/22/2024		
4/23/2024		
4/24/2024		
4/25/2024		
4/26/2024		
4/27/2024		
4/28/2024		
4/29/2024		
4/30/2024		

County: Multnomah Agency: Region 1

**Entry Point  
EP-B GWPS  
(Groundwater)**

**PWS ID: OR 4100657  
Portland Bureau of Water Works**

Month: **April 2024**

Sampling Period: **January to June 2024**

Total days minimum WQPs not met during this month, EP-B only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

**Minimum EP-B Water Quality  
Parameters (WQPs) as set by State:**

pH:	8.0 pH units
Alkalinity:	Not Applicable

**Print Name:** Anna Vosa, P.E.

**Signature:** 

**Date:** 5/7/24

**Total N's: N/A**