

Lead & Copper Rule Corrosion Control

Date	Average pH	Minimums Met? (Y / N)
7/1/2025		
7/2/2025		
7/3/2025		
7/4/2025		
7/5/2025		
7/6/2025		
7/7/2025		
7/8/2025		
7/9/2025		
7/10/2025		
7/11/2025		
7/12/2025		
7/13/2025		
7/14/2025		
7/15/2025		
7/16/2025		
7/17/2025		
7/18/2025		
7/19/2025		
7/20/2025		
7/21/2025		
7/22/2025	8.2	Y
7/23/2025	8.2	Y
7/24/2025	8.2	Y
7/25/2025	8.2	Y
7/26/2025	8.2	Y
7/27/2025	8.2	Y
7/28/2025	8.2	Y
7/29/2025	8.2	Y
7/30/2025	8.2	Y
7/31/2025	8.3	Y

Total N's: 0

Groundwater Not In Use

County: Multnomah Agency: Region 1

Entry Point
EP-B GWPS
(Groundwater)

PWS ID: OR 4100657
Portland Bureau of Water Works

Month: **July 2025**

Sampling Period: **July to December 2025**

Total days minimum WQPs not met during this month, EP-B only: **0**

Total Excursions (days minimum WQPs not met) during this
6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

Minimum EP-B Water Quality
Parameters (WQPs) as set by State:

pH	8.0 pH units
Alkalinity	Not Applicable

Print Name: Anna Vosa, P.E.

Signature: Anna Vosa

Date: 8/7/25