

Lead & Copper Rule Corrosion Control

Date	Average pH	Minimums Met? (Y / N)
8/1/2025	8.3	Y
8/2/2025	8.3	Y
8/3/2025	8.2	Y
8/4/2025	8.2	Y
8/5/2025	8.2	Y
8/6/2025	8.2	Y
8/7/2025	8.2	Y
8/8/2025	8.2	Y
8/9/2025	8.2	Y
8/10/2025	8.2	Y
8/11/2025	8.2	Y
8/12/2025	8.2	Y
8/13/2025	8.2	Y
8/14/2025	8.2	Y
8/15/2025	8.2	Y
8/16/2025	8.2	Y
8/17/2025	8.2	Y
8/18/2025	8.2	Y
8/19/2025	8.2	Y
8/20/2025	8.2	Y
8/21/2025	8.2	Y
8/22/2025	8.3	Y
8/23/2025	8.2	Y
8/24/2025	8.2	Y
8/25/2025	8.2	Y
8/26/2025	8.2	Y
8/27/2025	8.2	Y
8/28/2025	8.2	Y
8/29/2025	8.2	Y
8/30/2025	8.2	Y
8/31/2025	8.2	Y

Total N's: 0

Groundwater Not In Use

County: Multnomah Agency: Region 1

Entry Point
EP-B GWPS
(Groundwater)

PWS ID: OR 4100657
Portland Bureau of Water Works

Month: **August 2025**

Sampling Period: **July to December 2025**

Total days minimum WQPs not met during this month, EP-B only: **0**

Total Excursions (days minimum WQPs not met) during this
6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

Minimum EP-B Water Quality
Parameters (WQPs) as set by State:

pH	8.0 pH units
Alkalinity	Not Applicable

Print Name: Anna Vosa, P.E.

Signature: Anna Vosa

Date: 9/8/25