

Lead & Copper Rule Corrosion Control

Date	Average pH	Minimums Met? (Y / N)
12/1/2025		
12/2/2025		
12/3/2025		
12/4/2025		
12/5/2025		
12/6/2025	Groundwater	
12/7/2025	Not in Use	
12/8/2025		
12/9/2025		
12/10/2025		
12/11/2025		
12/12/2025		
12/13/2025		
12/14/2025		
12/15/2025		
12/16/2025		
12/17/2025		
12/18/2025		
12/19/2025	8.4	Y
12/20/2025	8.2	Y
12/21/2025	8.2	Y
12/22/2025	8.2	Y
12/23/2025	8.2	Y
12/24/2025	8.2	Y
12/25/2025	8.2	Y
12/26/2025	8.2	Y
12/27/2025		
12/28/2025	Groundwater	
12/29/2025	Not in Use	
12/30/2025		
12/31/2025		

Total N's: 0

Groundwater Not In Use

County: Multnomah Agency: Region 1

**Entry Point
EP-B GWPS
(Groundwater)**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **December 2025**

Sampling Period: **July to December 2025**

Total days minimum WQPs not met during this month, EP-B only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

**Minimum EP-B Water Quality
Parameters (WQPs) as set by State:**

pH	8.0 pH units
Alkalinity	Not Applicable

Print Name: Anna Vosa, P.E.

Signature: 

Date: 1/8/26