

Lead & Copper Rule Corrosion Control

| Date | Average pH | Minimums Met? (Y / N) |
|-----------|--------------------|-----------------------|
| 1/1/2026 | | |
| 1/2/2026 | | |
| 1/3/2026 | | |
| 1/4/2026 | | |
| 1/5/2026 | | |
| 1/6/2026 | | |
| 1/7/2026 | | |
| 1/8/2026 | | |
| 1/9/2026 | | |
| 1/10/2026 | | |
| 1/11/2026 | | |
| 1/12/2026 | | |
| 1/13/2026 | Groundwater | |
| 1/14/2026 | Not in Use | |
| 1/15/2026 | | |
| 1/16/2026 | | |
| 1/17/2026 | | |
| 1/18/2026 | | |
| 1/19/2026 | | |
| 1/20/2026 | | |
| 1/21/2026 | | |
| 1/22/2026 | | |
| 1/23/2026 | | |
| 1/24/2026 | | |
| 1/25/2026 | | |
| 1/26/2026 | | |
| 1/27/2026 | | |
| 1/28/2026 | | |
| 1/29/2026 | | |
| 1/30/2026 | | |
| 1/31/2026 | | |

Total N's: N/A

| |
|-------------------------------|
| Groundwater Not In Use |
|-------------------------------|

County: Multnomah Agency: Region 1

**Entry Point
EP-B GWPS
(Groundwater)**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **January 2026**

Sampling Period: **January to June 2026**

Total days minimum WQPs not met during this month, EP-B only: **0**

Total Excursions (days minimum WQPs not met) during this 6-month Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

**Minimum EP-B Water Quality
Parameters (WQPs) as set by State:**

| | |
|------------|----------------|
| pH | 8.0 pH units |
| Alkalinity | Not Applicable |

Print Name: Anna Vosa, P.E.

Signature: 

Date: 2/9/26