

Lead & Copper Rule Corrosion Control

County: Multnomah Agency: Region 1

Distribution System

DIST-A

Number of Samples Required: 10

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: 12/2024

Sampling Period: July to December 2024

Source water when sampled: 100% Bull Run
(100% Bull Run / 100% GW / GW-SW Blend)

	Collection Date	Sample ID	Sample Location	pH	Alkalinity	Minimums Met? (Y / N)
1	12/3/2024	BD23673	LCDWS001: 7310 SW Sylvan Ct., West Slope WD Site 1	8.6	31	Y
2	12/3/2024	BD23674	WQSS0011: 5600 Block SW Knightsbridge, Smith School	8.6	30	Y
3	12/3/2024	BD23675	WQSS0018: NW 24th & NW Hoyt	8.8	30	Y
4	12/3/2024	BD23676	WQSS0026: NE 106th & Sandy, Engine 48	8.8	30	Y
5	12/3/2024	BD23677	WQSS0030: SE Gideon & 13th Pl, Engine 23	8.7	30	Y
6	12/3/2024	BD23678	WQSS0034: N Syracuse and New York, St. Johns	8.8	30	Y
7	12/3/2024	BD23679	WQSS0062: SE Reedway and 92nd, Engine 11	8.7	30	Y
8	12/3/2024	BD23680	WQSS0184: NE 17th and Mason, Sabin Elementary School	8.8	31	Y
9	12/3/2024	BD23681	WQSS0217: SE 106th & Main, Adventist Hospital	8.8	30	Y
10	12/3/2024	BD23682	WQSS0256: NE 6th and Faloma	8.7	30	Y

Total N's: 0

Minimum DIST-A Water Quality Parameters (WQPs) as set by State:

pH:	8.4 pH units (100% Bull Run)
Alkalinity:	26 mg/L as CaCO ₃ (100% Bull Run)
pH:	7.6 pH units (100% GW and GW-SW blends)
Alkalinity:	Not Applicable (100% GW and GW-SW blends)

Number of DIST-A locations which did not meet minimum WQPs,
this sampling event: 0

Total Excursions (days minimum WQPs not met) during this 6-month
Sampling Period, all locations (EP-A, EP-B and DIST-A): 0

Is System in Compliance? Y

Print Name: Anna Vosa, P.E.

Signature: 

Date: 1/6/25