

Lead & Copper Rule Corrosion Control

County: Multnomah Agency: Region 1

Distribution System

DIST-A

Number of Samples Required: 10

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: 03/2026

Sampling Period: January to June 2026

Source water when sampled: 100% Bull Run
(100% Bull Run / 100% GW / GW-SW Blend)

Collection Date	Sample ID	Sample Location	pH	Alkalinity	Minimums Met? (Y / N)
1 3/17/2026	BD67880	LCDWS001: 7310 SW Sylvan Ct., West Slope WD Site 1	8.4	28	Y
2 3/17/2026	BD67881	WQSS0011: 5600 Block SW Knightsbridge, Smith School	8.5	27	Y
3 3/17/2026	BD67882	WQSS0018: NW 24th & NW Hoyt	8.5	27	Y
4 3/17/2026	BD67883	WQSS0026: NE 106th & Sandy, Engine 48	8.6	27	Y
5 3/17/2026	BD67884	WQSS0030: SE Gideon & 13th Pl, Engine 23	8.6	27	Y
6 3/17/2026	BD67885	WQSS0034: N Syracuse and New York, St. Johns	8.5	27	Y
7 3/17/2026	BD67886	WQSS0062: SE Reedway and 92nd, Engine 11	8.6	27	Y
8 3/17/2026	BD67887	WQSS0184: NE 17th and Mason, Sabin Elementary School	8.6	27	Y
9 3/17/2026	BD67888	WQSS0217: SE 106th & Main, Adventist Hospital	8.6	27	Y
10 3/17/2026	BD67889	WQSS0256: NE 6th and Faloma	8.5	27	Y

Total N's: 0

Minimum DIST-A Water Quality Parameters (WQPs) as set by State:

pH	8.4 pH units (100% Bull Run)
Alkalinity	26 mg/L as CaCO ₃ (100% Bull Run)
pH	7.6 pH units (100% GW and GW-SW blends)
Alkalinity	Not Applicable (100% GW and GW-SW blends)

Number of DIST-A locations which did not meet minimum WQPs,
this sampling event: **0**

Total Excursions (days minimum WQPs not met) during this 6-month
Sampling Period, all locations (EP-A, EP-B and DIST-A): **0**

Is System in Compliance? **Y**

Print Name: Anna Vosa, P.E.

Signature: Anna Vosa

Date: 4/8/26