

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
3/1/2021	8.2	Y
3/2/2021	8.2	Y
3/3/2021	8.2	Y
3/4/2021	8.2	Y
3/5/2021	8.2	Y
3/6/2021	8.2	Y
3/7/2021	8.2	Y
3/8/2021	8.3	Y
3/9/2021	8.3	Y
3/10/2021	8.2	Y
3/11/2021	8.2	Y
3/12/2021	8.2	Y
3/13/2021	8.2	Y
3/14/2021	8.2	Y
3/15/2021	8.2	Y
3/16/2021	8.3	Y
3/17/2021	8.2	Y
3/18/2021	8.2	Y
3/19/2021	8.2	Y
3/20/2021	8.2	Y
3/21/2021	8.2	Y
3/22/2021	8.2	Y
3/23/2021	8.2	Y
3/24/2021	8.2	Y
3/25/2021	8.2	Y
3/26/2021	8.3	Y
3/27/2021	8.2	Y
3/28/2021	8.2	Y
3/29/2021	8.3	Y
3/30/2021	8.3	Y
3/31/2021	8.2	Y

County: Multnomah Agency: Region 1

Entry Point

EP-A

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: **March 2021**

Sampling Period: **January to June 2021**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: 

Date: 4/7/21

Total No's: 0