

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
5/1/2021	8.3	Y
5/2/2021	8.2	Y
5/3/2021	8.3	Y
5/4/2021	8.3	Y
5/5/2021	8.2	Y
5/6/2021	8.2	Y
5/7/2021	8.3	Y
5/8/2021	8.2	Y
5/9/2021	8.2	Y
5/10/2021	8.2	Y
5/11/2021	8.2	Y
5/12/2021	8.2	Y
5/13/2021	8.2	Y
5/14/2021	8.2	Y
5/15/2021	8.2	Y
5/16/2021	8.2	Y
5/17/2021	8.2	Y
5/18/2021	8.2	Y
5/19/2021	8.2	Y
5/20/2021	8.2	Y
5/21/2021	8.2	Y
5/22/2021	8.2	Y
5/23/2021	8.2	Y
5/24/2021	8.2	Y
5/25/2021	8.2	Y
5/26/2021	8.0	Y
5/27/2021	8.2	Y
5/28/2021	8.2	Y
5/29/2021	8.2	Y
5/30/2021	8.2	Y
5/31/2021	8.2	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **May 2021**

Sampling Period: **January to June 2021**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: 

Date: 6/4/21

Total No's: 0