

Lead & Copper Rule Corrosion Control

| Date | Average Daily pH | Minimum Met? |
|-----------|------------------|--------------|
| 6/1/2021 | 8.2 | Y |
| 6/2/2021 | 8.3 | Y |
| 6/3/2021 | 8.2 | Y |
| 6/4/2021 | 8.2 | Y |
| 6/5/2021 | 8.2 | Y |
| 6/6/2021 | 8.3 | Y |
| 6/7/2021 | 8.2 | Y |
| 6/8/2021 | 8.3 | Y |
| 6/9/2021 | 8.2 | Y |
| 6/10/2021 | 8.2 | Y |
| 6/11/2021 | 8.2 | Y |
| 6/12/2021 | 8.2 | Y |
| 6/13/2021 | 8.3 | Y |
| 6/14/2021 | 8.2 | Y |
| 6/15/2021 | 8.2 | Y |
| 6/16/2021 | 8.3 | Y |
| 6/17/2021 | 8.2 | Y |
| 6/18/2021 | 8.3 | Y |
| 6/19/2021 | 8.3 | Y |
| 6/20/2021 | 8.2 | Y |
| 6/21/2021 | 8.2 | Y |
| 6/22/2021 | 8.2 | Y |
| 6/23/2021 | 8.2 | Y |
| 6/24/2021 | 8.1 | Y |
| 6/25/2021 | 8.2 | Y |
| 6/26/2021 | 8.2 | Y |
| 6/27/2021 | 8.3 | Y |
| 6/28/2021 | 8.2 | Y |
| 6/29/2021 | 8.2 | Y |
| 6/30/2021 | 8.2 | Y |

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **June 2021**

Sampling Period: **January to June 2021**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

| | |
|---|------------|
| Minimum Water Quality Parameter as Set by State: | |
| pH | 8.0 |

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 7/7/21

Total No's: 0