

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
7/1/2021	8.1	Y
7/2/2021	8.2	Y
7/3/2021	8.2	Y
7/4/2021	8.3	Y
7/5/2021	8.2	Y
7/6/2021	8.2	Y
7/7/2021	8.3	Y
7/8/2021	8.3	Y
7/9/2021	8.2	Y
7/10/2021	8.2	Y
7/11/2021	8.2	Y
7/12/2021	8.2	Y
7/13/2021	8.2	Y
7/14/2021	8.2	Y
7/15/2021	8.2	Y
7/16/2021	8.2	Y
7/17/2021	8.2	Y
7/18/2021	8.2	Y
7/19/2021	8.2	Y
7/20/2021	8.2	Y
7/21/2021	8.2	Y
7/22/2021	8.2	Y
7/23/2021	8.2	Y
7/24/2021	8.2	Y
7/25/2021	8.2	Y
7/26/2021	8.2	Y
7/27/2021	8.2	Y
7/28/2021	8.2	Y
7/29/2021	8.2	Y
7/30/2021	8.2	Y
7/31/2021	8.2	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **July 2021**

Sampling Period: **July to December 2021**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 8/6/21

Total No's: 0