

# Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
9/1/2021	8.2	Y
9/2/2021	8.2	Y
9/3/2021	8.2	Y
9/4/2021	8.2	Y
9/5/2021	8.2	Y
9/6/2021	8.3	Y
9/7/2021	8.2	Y
9/8/2021	8.2	Y
9/9/2021	8.2	Y
9/10/2021	8.2	Y
9/11/2021	8.3	Y
9/12/2021	8.2	Y
9/13/2021	8.3	Y
9/14/2021	8.2	Y
9/15/2021	8.2	Y
9/16/2021	8.3	Y
9/17/2021	8.3	Y
9/18/2021	8.3	Y
9/19/2021	8.3	Y
9/20/2021	8.2	Y
9/21/2021	8.3	Y
9/22/2021	8.2	Y
9/23/2021	8.3	Y
9/24/2021	8.3	Y
9/25/2021	8.2	Y
9/26/2021	8.2	Y
9/27/2021	8.3	Y
9/28/2021	8.3	Y
9/29/2021	8.2	Y
9/30/2021	8.2	Y

County: Multnomah Agency: Region 1

**Entry Point  
EP-A**

**PWS ID: OR 4100657  
Portland Bureau of Water Works**

Month: **September 2021**

Sampling Period: **July to December 2021**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**  
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:
---

<b>pH</b>	<b>8.0</b>
-----------	------------

Print Name: Anna Vosa, P.E.

Signature: 

Date: 10/7/21

**Total No's: 0**