

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
2/1/2022	8.3	Y
2/2/2022	8.3	Y
2/3/2022	8.3	Y
2/4/2022	8.3	Y
2/5/2022	8.3	Y
2/6/2022	8.3	Y
2/7/2022	8.3	Y
2/8/2022	8.3	Y
2/9/2022	100 Percent Groundwater	
2/10/2022		
2/11/2022	8.1	Y
2/12/2022	8.4	Y
2/13/2022	8.4	Y
2/14/2022	8.3	Y
2/15/2022	8.3	Y
2/16/2022	8.3	Y
2/17/2022	8.3	Y
2/18/2022	8.3	Y
2/19/2022	8.3	Y
2/20/2022	8.3	Y
2/21/2022	8.3	Y
2/22/2022	8.3	Y
2/23/2022	8.4	Y
2/24/2022	8.4	Y
2/25/2022	8.3	Y
2/26/2022	8.4	Y
2/27/2022	8.4	Y
2/28/2022	8.4	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **February 2022**

Sampling Period: **January to June 2022**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:

pH	8.0
-----------	------------

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 3/9/22

Total No's: 0