

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
3/1/2022	8.3	Y
3/2/2022	8.3	Y
3/3/2022	8.3	Y
3/4/2022	8.4	Y
3/5/2022	8.3	Y
3/6/2022	8.3	Y
3/7/2022	8.3	Y
3/8/2022	8.3	Y
3/9/2022	8.4	Y
3/10/2022	8.3	Y
3/11/2022	8.3	Y
3/12/2022	8.3	Y
3/13/2022	8.3	Y
3/14/2022	8.3	Y
3/15/2022	8.3	Y
3/16/2022	8.4	Y
3/17/2022	8.4	Y
3/18/2022	8.3	Y
3/19/2022	8.3	Y
3/20/2022	8.3	Y
3/21/2022	8.3	Y
3/22/2022	8.3	Y
3/23/2022	8.3	Y
3/24/2022	8.3	Y
3/25/2022	8.3	Y
3/26/2022	8.3	Y
3/27/2022	8.3	Y
3/28/2022	8.3	Y
3/29/2022	8.4	Y
3/30/2022	8.3	Y
3/31/2022	8.3	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **March 2022**

Sampling Period: **January to June 2022**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: 

Date: 4/6/22

Total No's: 0