

# Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
5/1/2022	8.4	Y
5/2/2022	8.4	Y
5/3/2022	8.4	Y
5/4/2022	8.4	Y
5/5/2022	8.4	Y
5/6/2022	8.4	Y
5/7/2022	8.4	Y
5/8/2022	8.4	Y
5/9/2022	8.4	Y
5/10/2022	8.4	Y
5/11/2022	8.4	Y
5/12/2022	8.4	Y
5/13/2022	8.4	Y
5/14/2022	8.2	Y
5/15/2022	8.3	Y
5/16/2022	8.3	Y
5/17/2022	8.3	Y
5/18/2022	8.4	Y
5/19/2022	8.4	Y
5/20/2022	8.4	Y
5/21/2022	8.4	Y
5/22/2022	8.4	Y
5/23/2022	8.4	Y
5/24/2022	8.5	Y
5/25/2022	8.5	Y
5/26/2022	8.6	Y
5/27/2022	8.5	Y
5/28/2022	8.5	Y
5/29/2022	8.5	Y
5/30/2022	8.5	Y
5/31/2022	8.6	Y

County: Multnomah Agency: Region 1

**Entry Point**

**EP-A**

**PWS ID: OR 4100657**

**Portland Bureau of Water Works**

Month: **May 2022**

Sampling Period: **January to June 2022**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**  
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:
---

<b>pH</b>	<b>8.0</b>
-----------	------------

**Print Name:** Anna Vosa, P.E.

**Signature:** *Anna Vosa*

**Date:** 6/8/22

**Total No's: 0**