

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
9/1/2022	8.9	Y
9/2/2022	8.9	Y
9/3/2022	8.9	Y
9/4/2022	8.8	Y
9/5/2022	8.9	Y
9/6/2022	8.9	Y
9/7/2022	8.9	Y
9/8/2022	8.9	Y
9/9/2022	8.8	Y
9/10/2022	8.9	Y
9/11/2022	8.9	Y
9/12/2022	8.9	Y
9/13/2022	8.9	Y
9/14/2022	8.9	Y
9/15/2022	8.9	Y
9/16/2022	8.9	Y
9/17/2022	8.9	Y
9/18/2022	8.9	Y
9/19/2022	8.8	Y
9/20/2022	8.9	Y
9/21/2022	8.8	Y
9/22/2022	8.8	Y
9/23/2022	8.9	Y
9/24/2022	8.9	Y
9/25/2022	8.9	Y
9/26/2022	8.8	Y
9/27/2022	8.8	Y
9/28/2022	8.8	Y
9/29/2022	8.9	Y
9/30/2022	8.9	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **September 2022**

Sampling Period: **July to December 2022**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: 

Date: 10/5/22

Total No's: 0