

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
10/1/2022	8.9	Y
10/2/2022	8.9	Y
10/3/2022	8.8	Y
10/4/2022	8.9	Y
10/5/2022	8.9	Y
10/6/2022	8.8	Y
10/7/2022	8.8	Y
10/8/2022	8.9	Y
10/9/2022	8.9	Y
10/10/2022	8.9	Y
10/11/2022	8.9	Y
10/12/2022	8.9	Y
10/13/2022	8.9	Y
10/14/2022	8.8	Y
10/15/2022	8.8	Y
10/16/2022	8.9	Y
10/17/2022	8.8	Y
10/18/2022	8.7	Y
10/19/2022	8.9	Y
10/20/2022	8.9	Y
10/21/2022	8.9	Y
10/22/2022	8.9	Y
10/23/2022	8.9	Y
10/24/2022	8.9	Y
10/25/2022	8.9	Y
10/26/2022	8.8	Y
10/27/2022	8.8	Y
10/28/2022	8.8	Y
10/29/2022	8.8	Y
10/30/2022	8.8	Y
10/31/2022	8.8	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **October 2022**

Sampling Period: **July to December 2022**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 11/7/22

Total No's: 0