

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
11/1/2022	8.8	Y
11/2/2022	8.8	Y
11/3/2022	8.7	Y
11/4/2022	8.8	Y
11/5/2022	8.7	Y
11/6/2022		
11/7/2022		
11/8/2022		
11/9/2022		
11/10/2022	Supply	
11/11/2022	100% Groundwater	
11/12/2022		
11/13/2022		
11/14/2022		
11/15/2022		
11/16/2022		
11/17/2022		
11/18/2022		
11/19/2022		
11/20/2022		
11/21/2022	7.1	N
11/22/2022	7.3	N
11/23/2022	8.5	Y
11/24/2022	8.9	Y
11/25/2022	9.0	Y
11/26/2022	8.9	Y
11/27/2022	8.9	Y
11/28/2022	8.9	Y
11/29/2022	8.8	Y
11/30/2022	8.8	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **November 2022**

Sampling Period: **July to December 2022**

Number of Excursions During this Month: **2**

Total Excursions During this Sampling Period: **2**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:

pH	8.0
-----------	------------

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 12/8/22

Total No's: 2