

# Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
1/1/2023	9.0	Y
1/2/2023	9.0	Y
1/3/2023	9.0	Y
1/4/2023	8.9	Y
1/5/2023	8.9	Y
1/6/2023	8.9	Y
1/7/2023	9.0	Y
1/8/2023	9.0	Y
1/9/2023	8.9	Y
1/10/2023	8.9	Y
1/11/2023	8.9	Y
1/12/2023	8.8	Y
1/13/2023	8.8	Y
1/14/2023	8.9	Y
1/15/2023	8.9	Y
1/16/2023	8.9	Y
1/17/2023	8.9	Y
1/18/2023	8.9	Y
1/19/2023	8.9	Y
1/20/2023	8.9	Y
1/21/2023	8.9	Y
1/22/2023	8.9	Y
1/23/2023	8.9	Y
1/24/2023	8.9	Y
1/25/2023	8.9	Y
1/26/2023	8.9	Y
1/27/2023	8.9	Y
1/28/2023	8.9	Y
1/29/2023	8.9	Y
1/30/2023	8.9	Y
1/31/2023	8.9	Y

County: Multnomah Agency: Region 1

**Entry Point**

**EP-A**

**PWS ID: OR 4100657**

**Portland Bureau of Water Works**

Month: **January 2023**

Sampling Period: **January to June 2023**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**  
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:
---

<b>pH</b>	<b>8.0</b>
-----------	------------

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 2/3/2023

**Total No's: 0**