

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
3/1/2023	8.9	Y
3/2/2023	8.9	Y
3/3/2023	8.9	Y
3/4/2023	8.9	Y
3/5/2023	8.9	Y
3/6/2023	8.9	Y
3/7/2023	8.9	Y
3/8/2023	8.9	Y
3/9/2023	8.9	Y
3/10/2023	9.0	Y
3/11/2023	8.9	Y
3/12/2023	8.9	Y
3/13/2023	8.9	Y
3/14/2023	8.9	Y
3/15/2023	8.9	Y
3/16/2023	8.9	Y
3/17/2023	8.9	Y
3/18/2023	8.9	Y
3/19/2023	8.8	Y
3/20/2023	8.8	Y
3/21/2023	8.8	Y
3/22/2023	8.9	Y
3/23/2023	8.9	Y
3/24/2023	8.9	Y
3/25/2023	8.9	Y
3/26/2023	8.9	Y
3/27/2023	8.9	Y
3/28/2023	8.9	Y
3/29/2023	8.9	Y
3/30/2023	8.9	Y
3/31/2023	8.8	Y

County: Multnomah Agency: Region 1

Entry Point

EP-A

PWS ID: OR 4100657

Portland Bureau of Water Works

Month: **March 2023**

Sampling Period: **January to June 2023**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:

pH	8.0
-----------	------------

Print Name: Anna Vosa, P.E.

Signature: 

Date: 4/6/2023

Total No's: 0