

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
4/1/2023	8.8	Y
4/2/2023	8.9	Y
4/3/2023	8.9	Y
4/4/2023	8.9	Y
4/5/2023	8.8	Y
4/6/2023	8.9	Y
4/7/2023	8.8	Y
4/8/2023	8.8	Y
4/9/2023	8.8	Y
4/10/2023	8.8	Y
4/11/2023	8.9	Y
4/12/2023	8.8	Y
4/13/2023	8.9	Y
4/14/2023	8.9	Y
4/15/2023	8.9	Y
4/16/2023	8.9	Y
4/17/2023	8.9	Y
4/18/2023	8.9	Y
4/19/2023	8.9	Y
4/20/2023	8.9	Y
4/21/2023	8.9	Y
4/22/2023	8.9	Y
4/23/2023	8.9	Y
4/24/2023	8.9	Y
4/25/2023	8.9	Y
4/26/2023	8.9	Y
4/27/2023	8.9	Y
4/28/2023	8.9	Y
4/29/2023	8.9	Y
4/30/2023	8.9	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **April 2023**

Sampling Period: **January to June 2023**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:

pH	8.0
-----------	------------

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 5/8/23

Total No's: 0