

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
6/1/2023	8.9	Y
6/2/2023	8.9	Y
6/3/2023	8.9	Y
6/4/2023	8.9	Y
6/5/2023	8.9	Y
6/6/2023	8.9	Y
6/7/2023	8.9	Y
6/8/2023	8.9	Y
6/9/2023	8.9	Y
6/10/2023	8.8	Y
6/11/2023	8.9	Y
6/12/2023	8.9	Y
6/13/2023	8.9	Y
6/14/2023	9.0	Y
6/15/2023	8.9	Y
6/16/2023	8.9	Y
6/17/2023	8.9	Y
6/18/2023	8.9	Y
6/19/2023	8.9	Y
6/20/2023	8.9	Y
6/21/2023	8.9	Y
6/22/2023	8.9	Y
6/23/2023	8.9	Y
6/24/2023	8.9	Y
6/25/2023	8.9	Y
6/26/2023	8.9	Y
6/27/2023	8.9	Y
6/28/2023	8.9	Y
6/29/2023	8.9	Y
6/30/2023	8.9	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-A**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **June 2023**

Sampling Period: **January to June 2023**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 7/6/23

Total No's: 0