

# Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
2/1/2022		
2/2/2022		
2/3/2022	Groundwater Not in Use	
2/4/2022		
2/5/2022		
2/6/2022		
2/7/2022		
2/8/2022	8.3	Y
2/9/2022	8.2	Y
2/10/2022	8.3	Y
2/11/2022	8.2	Y
2/12/2022		
2/13/2022		
2/14/2022		
2/15/2022		
2/16/2022	Groundwater not in use	
2/17/2022		
2/18/2022		
2/19/2022		
2/20/2022		
2/21/2022		
2/22/2022		
2/23/2022		
2/24/2022		
2/25/2022		
2/26/2022		
2/27/2022		
2/28/2022		

**Total No's:            0**

County: Multnomah Agency: Region 1

**Entry Point  
EP-B**

**PWS ID: OR 4100657  
Portland Bureau of Water Works**

Month:                            **February 2022**

Sampling Period:            **January to June 2022**

Number of Excursions During this Month:    **0**

Total Excursions During this Sampling Period:    **0**  
(Including Distribution System Excursions)

Is System in Compliance?    **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
<b>pH</b>	<b>8.0</b>

**Print Name:** Anna Vosa, P.E.

**Signature:** 

**Date:** 3/9/22