

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
10/1/2022		
10/2/2022		
10/3/2022		
10/4/2022		
10/5/2022		
10/6/2022	Groundwater	
10/7/2022	Not in Use	
10/8/2022		
10/9/2022		
10/10/2022		
10/11/2022		
10/12/2022		
10/13/2022	8.4	Y
10/14/2022	8.3	Y
10/15/2022	8.3	Y
10/16/2022	8.3	Y
10/17/2022	8.3	Y
10/18/2022	8.3	Y
10/19/2022	8.3	Y
10/20/2022	8.2	Y
10/21/2022	8.2	Y
10/22/2022	8.2	Y
10/23/2022	8.3	Y
10/24/2022	8.3	Y
10/25/2022	8.3	Y
10/26/2022	8.3	Y
10/27/2022	8.3	Y
10/28/2022	8.2	Y
10/29/2022	8.2	Y
10/30/2022	8.2	Y
10/31/2022	8.2	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-B**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **October 2022**

Sampling Period: **July to December 2022**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: 

Date: 11/7/22

Total No's: 0