

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
11/1/2022	8.2	Y
11/2/2022	8.2	Y
11/3/2022	8.2	Y
11/4/2022	GW Not in Use	
11/5/2022	8.2	Y
11/6/2022	8.2	Y
11/7/2022	8.3	Y
11/8/2022	8.3	Y
11/9/2022	8.2	Y
11/10/2022	8.3	Y
11/11/2022	8.2	Y
11/12/2022	8.2	Y
11/13/2022	8.2	Y
11/14/2022	8.2	Y
11/15/2022	8.3	Y
11/16/2022	8.3	Y
11/17/2022	8.2	Y
11/18/2022	8.2	Y
11/19/2022	8.2	Y
11/20/2022	8.2	Y
11/21/2022	8.2	Y
11/22/2022	8.6	Y
11/23/2022	8.3	Y
11/24/2022		
11/25/2022		
11/26/2022	Groundwater	
11/27/2022	Not in Use	
11/28/2022		
11/29/2022		
11/30/2022		

County: Multnomah Agency: Region 1

**Entry Point
EP-B**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **November 2022**

Sampling Period: **July to December 2022**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **2**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: 

Date: 12/8/22

Total No's: 0