

# Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
1/1/2023		
1/2/2023		
1/3/2023		
1/4/2023		
1/5/2023		
1/6/2023		
1/7/2023		
1/8/2023		
1/9/2023		
1/10/2023		
1/11/2023		
1/12/2023		
1/13/2023		
1/14/2023	Groundwater	
1/15/2023	Not in Use	
1/16/2023		
1/17/2023		
1/18/2023		
1/19/2023		
1/20/2023		
1/21/2023		
1/22/2023		
1/23/2023		
1/24/2023		
1/25/2023		
1/26/2023		
1/27/2023		
1/28/2023		
1/29/2023		
1/30/2023		
1/31/2023		

County: Multnomah Agency: Region 1

**Entry Point  
EP-B**

**PWS ID: OR 4100657  
Portland Bureau of Water Works**

Month: **January 2023**

Sampling Period: **January to June 2023**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**  
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:
---

<b>pH</b>	<b>8.0</b>
-----------	------------

**Print Name:** Anna Vosa, P.E.

**Signature:**

**Date:** 2/3/2023

**Total No's: N/A**