

# Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
3/1/2023		
3/2/2023		
3/3/2023		
3/4/2023		
3/5/2023		
3/6/2023		
3/7/2023		
3/8/2023		
3/9/2023		
3/10/2023		
3/11/2023		
3/12/2023		
3/13/2023		
3/14/2023	Groundwater	
3/15/2023	Not in Use	
3/16/2023		
3/17/2023		
3/18/2023		
3/19/2023		
3/20/2023		
3/21/2023		
3/22/2023		
3/23/2023		
3/24/2023		
3/25/2023		
3/26/2023		
3/27/2023		
3/28/2023		
3/29/2023		
3/30/2023		
3/31/2023		

County: Multnomah Agency: Region 1

**Entry Point  
EP-B**

**PWS ID: OR 4100657  
Portland Bureau of Water Works**

Month: **March 2023**

Sampling Period: **January to June 2023**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**  
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:
---

<b>pH</b>	<b>8.0</b>
-----------	------------

Print Name: Anna Vosa, P.E.

Signature: 

Date: 4/6/2023

**Total No's: N/A**