

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
7/1/2023		
7/2/2023		
7/3/2023		
7/4/2023		
7/5/2023		
7/6/2023		
7/7/2023		
7/8/2023		
7/9/2023		
7/10/2023		
7/11/2023		
7/12/2023		
7/13/2023		
7/14/2023	Groundwater	
7/15/2023	Not in Use	
7/16/2023		
7/17/2023		
7/18/2023		
7/19/2023		
7/20/2023		
7/21/2023		
7/22/2023		
7/23/2023		
7/24/2023		
7/25/2023		
7/26/2023		
7/27/2023		
7/28/2023		
7/29/2023		
7/30/2023		
7/31/2023		

County: Multnomah Agency: Region 1

**Entry Point
EP-B**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **July 2023**

Sampling Period: **July to December 2023**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:	
pH	8.0

Print Name: Anna Vosa, P.E.

Signature: 

Date: 8/8/23

Total No's: N/A