

Lead & Copper Rule Corrosion Control

Date	Average Daily pH	Minimum Met?
8/1/2023		
8/2/2023		
8/3/2023		
8/4/2023		
8/5/2023		
8/6/2023		
8/7/2023	Groundwater	
8/8/2023	Not in Use	
8/9/2023		
8/10/2023		
8/11/2023		
8/12/2023		
8/13/2023		
8/14/2023		
8/15/2023		
8/16/2023		
8/17/2023		
8/18/2023		
8/19/2023		
8/20/2023		
8/21/2023		
8/22/2023		
8/23/2023		
8/24/2023	8.5	Y
8/25/2023	8.4	Y
8/26/2023	8.3	Y
8/27/2023	8.2	Y
8/28/2023	8.3	Y
8/29/2023	8.3	Y
8/30/2023	8.3	Y
8/31/2023	8.3	Y

County: Multnomah Agency: Region 1

**Entry Point
EP-B**

**PWS ID: OR 4100657
Portland Bureau of Water Works**

Month: **August 2023**

Sampling Period: **July to December 2023**

Number of Excursions During this Month: **0**

Total Excursions During this Sampling Period: **0**
(Including Distribution System Excursions)

Is System in Compliance? **Y**

Reference

Minimum Water Quality Parameter as Set by State:

pH	8.0
-----------	------------

Print Name: Anna Vosa, P.E.

Signature: *Anna Vosa*

Date: 9/8/23

Total No's: N/A