

Water Quality Parameter Monitoring Form  
**Lead Copper Rule Corrosion Control**  
**DISTRIBUTION**

PWS ID: 4100657

Sample Date: 08/09/21

System Name: Portland Bureau of Water Works

Sample Period: July to December 2021

# of Distribution Samples Required: 25

Has sample met the minimums?

ID #	Sample Location	pH	Alk	Y/N
BC60386	DOLPH & 17TH, 1618 SW Dolph St. by 17th (WQSS0010)	7.9	49.0	Y
BC60387	SMITH SCHOOL, 5635 SW Knights Bridge (WQSS0011)	7.9	50.0	Y
BC60388	ZOO, NL Zoo Prkg Lot E of Booth (WQSS0016)	8.0	50.0	Y
BC60389	19TH & EVERETT, 1819 NW Everett on 19th (WQSS0017)	8.3	48.0	Y
BC60390	24TH & HOYT, 2386 NW Hoyt on 24th (WQSS0018)	8.3	48.0	Y
BC60391	ENG 23, 1305 SE Gideon (WQSS0030)	8.2	50.0	Y
BC60392	ST. JOHNS PRECINCT, 7031 N NewYork (WQSS0034)	8.2	50.0	Y
BC60393	Calvary Outlet -NW (WQSS0089)	7.9	50.0	Y
BC60394	BURRAGE & ARGYLE (WQSS0161)	8.2	50.0	Y
BC60395	SW 19th & Stephenson (WQSS0199)	8.2	47.0	Y
BC60396	SW 42nd & Cullen (WQSS0214)	8.3	49.0	Y
BC60397	NE 6th and Faloma (WQSS0256)	8.1	48.0	Y
BC60398	SITE #1 (LCDWS001)	8.4	42.0	Y

Number of excursions during this Sample Period: 0

(Count the number of locations when any WQP was less than the minimum)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Minimum Water Quality Parameters as set by State: pH 7.6

Print Name: Anna Vosa, P.E.

Signature:  Date: 9/8/21

Send to OHA within 10 days after end of sampling period

Oregon Health Authority – Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405

Water Quality Parameter Monitoring Form  
**Lead Copper Rule Corrosion Control**  
**DISTRIBUTION**

PWS ID: 4100657

Sample Date: 08/10/21

System Name: Portland Bureau of Water Works

Sample Period: July to December 2021

# of Distribution Samples Required: 25

Has sample met the minimums?

ID #	Sample Location	pH	Alk	Y/N
BC60373	52ND & MADISON, 1330 SE 52nd Ave (WQSS0002)	8.2	50.0	Y
BC60374	60TH & MAIN, 1322 SE 60th Ave (WQSS0006)	8.3	51.0	Y
BC60375	DUNIWAY SCHOOL, 7812 SE Reed College PI (WQSS0009)	8.2	50.0	Y
BC60376	PORTLAND AIRPORT, 7700 NE Airport Way (WQSS0024)	8.2	50.0	Y
BC60377	Engine 40 -NE (WQSS0025)	8.2	51.0	Y
BC60378	ENG 48, 4804 NE 106th Ave by Sandy (WQSS0026)	8.2	45.0	Y
BC60379	TENINO CT & CLATSOP, 9590 SE Tenino Ct (WQSS0028)	8.2	50.0	Y
BC60380	ENG 11, 5707 SE Reedway by 92nd (WQSS0062)	8.2	51.0	Y
BC60381	5109 SE 118TH AVE. (PV-4) (WQSS0118)	8.1	50.0	Y
BC60382	98TH & CLINTON (PV-10) (WQSS0124)	8.2	51.0	Y
BC60383	3928 SE 136TH AVE. (PV-29) (WQSS0143)	8.2	38.0	Y
BC60384	Sabin Elementary School -NE (WQSS0184)	8.1	51.0	Y
BC60385	Portland Adventist Hospital -SE (WQSS0217)	8.2	50.0	Y

Number of excursions during this Sample Period: 0

(Count the number of locations when any WQP was less than the minimum)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Minimum Water Quality Parameters as set by State: pH 7.6

Print Name: Anna Vosa, P.E.

Signature:  Date: 9/8/21

Send to OHA within 10 days after end of sampling period

Oregon Health Authority – Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405