

Lead & Copper Rule Corrosion Control

Water Quality Parameter Form - ENTRY POINT C (GRABHORN ASR)

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: February 2022

Frequency: Bi-weekly at EP while operating. Report each month even if not running.

| Day | Time | Cl2 | Cond | Temp | pH | pH Min met? |
|-----|---|------|------|------|------|-------------|
| 1 | Start of C16 recharge (Feb 2) | | | | | |
| 2 | 10:17 | 0.82 | 110 | 6.7 | 7.82 | |
| 3 | | | | | | |
| 4 | | | | | | |
| 5 | | | | | | |
| 6 | | | | | | |
| 7 | | | | | | |
| 8 | 4:08 | 0.86 | 115 | 6.8 | 7.82 | |
| 9 | | | | | | |
| 10 | | | | | | |
| 11 | | | | | | |
| 12 | | | | | | |
| 13 | | | | | | |
| 14 | | | | | | |
| 15 | Injection paused - transducer failed | | | | | |
| 16 | will continue recharge in March when new transducer arrives | | | | | |
| 17 | | | | | | |
| 18 | | | | | | |
| 19 | | | | | | |
| 20 | | | | | | |
| 21 | | | | | | |
| 22 | | | | | | |
| 23 | | | | | | |
| 24 | | | | | | |
| 25 | | | | | | |
| 26 | | | | | | |
| 27 | | | | | | |
| 28 | | | | | | |
| 29 | | | | | | |
| 30 | | | | | | |
| 31 | | | | | | |

Total excursions during previous five months: **0**

(Over 9 excursions in 6 months is a violation. EP and Distribution excursions are cumulative)

| | |
|---|-----|
| For OHA use only: | |
| Minimum Water Quality Parameters as set by OHA: | |
| pH | 7.4 |
| Alk | n/a |
| PO4 | n/a |

Total number of excursions for the month =

0

Other

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Print Name: William Richmond
 Signature: *William Richmond*
 Date: 3.03.22