

Lead & Copper Rule Corrosion Control

Water Quality Parameter Form - ENTRY POINT C (GRABHORN ASR)

PWS Name/ID: Tualatin Valley Water District/4100665

Monitoring Period: September 2022

Frequency: Bi-weekly at EP while operating. Report each month even if not running.

Notes: ASR Recovery dates: Sept. 6 - 21

Day	Time	Cl2	Cond	Temp	pH	pH Min met?	
1							
2							
3							
4							
5							
6	11:00	0.81	144	12.5	7.61	yes	
7							
8							
9							
10							
11							
12							
13							
14	11:05	0.79	165	11.2	7.71	yes	
15							
16							
17							
18							
19							
20							
21	9:39	0.84	150	11.2	7.68	yes	
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
Total number of excursions for the month =						0	Other

For OHA use only:	
Minimum Water Quality Parameters as set by OHA:	
pH	7.4
Alk	n/a
PO4	n/a

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Total excursions in previous 5 months: 0

> 9 excursions in 6 months = violation

Print Name: William Richmond

Signature: *William Richmond*

(EP and Dist. excursions are cumulative)

Date:

9.29.22