

Lead & Copper Rule Corrosion Control

Water Quality Parameters - ENTRY POINT C (GRABHORN ASR)

PWS Name/ID: Tualatin Valley Water District/4100665

Monitoring Period: September 2023

Frequency: Min. bi-weekly onsite monitoring while operating. Monthly report even if not running.

Notes: Started recovery on Sept 26 @ 1700 gpm

Day	Time	Cl2	Cond	Temp	pH	pH Min met?	Notes	
1							Well Off	
2							Well Off	
3							Well Off	
4							Well Off	
5							Well Off	
6							Well Off	
7							Well Off	
8							Well Off	
9							Well Off	
10							Well Off	
11							Well Off	
12							Well Off	
13							Well Off	
14							Well Off	
15							Well Off	
16							Well Off	
17							Well Off	
18							Well Off	
19							Well Off	
20							Well Off	
21							Well Off	
22							Well Off	
23							Well Off	
24							Well Off	
25							Well Off	
26	10:40	0.95	123	9.9	8.05	yes	began recovery	For OHA use only: Minimum Water Quality Parameters as set by OHA:
27								
28								
29								
30								
31								
Total number of excursions for the month =						0		Other

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Total excursions in previous 5 months: 0

> 9 excursions in 6 months = violation

(EP and Dist. excursions are cumulative)

Signature:

William Richmond

Date:

10.05.23