

### Lead & Copper Rule Corrosion Control

Water Quality Parameters - ENTRY POINT C (GRABHORN ASR)

**PWS Name/ID:** Tualatin Valley Water District/4100665

**Monitoring Period:** October 2023

**Frequency:** Min. bi-weekly onsite monitoring while operating. Monthly report even if not running.

**Notes:** Shut down well - end of Cycle 17

Day	Time	Cl2	Cond	Temp	pH	pH Min met?	Notes
1							Well running
2							Well running
3	10:30	0.95	134	10.3	7.98	yes	Well running
4							Well running
5							Well running
6							Well running
7							Well running
8							Well running
9							Well running
10							Well running
11							Well running
12							Well running
13	10:00	0.85	157	11.3	7.92	yes	Well running
14							Well running
15							Well running
16	11:00	1.01	171	11	7.84	yes	Well running
17							Well Off
18							Well Off
19							Well Off
20							Well Off
21							Well Off
22							Well Off
23							Well Off
24							Well Off
25							Well Off
26							Well Off
27							Well Off
28							Well Off
29							Well Off
30							Well Off
31							Well Off
Total number of excursions for the month =						0	

For OHA use only:	
Minimum Water Quality Parameters as set by OHA:	
pH	7.4
Alk	n/a
PO4	n/a
Other	

Send to [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us) within 10 days after end of sampling period

**Total excursions in previous 5 months: 0**

> 9 excursions in 6 months = violation

(EP and Dist. excursions are cumulative)

Signature:

*William Richmond*

Date:

11.08.23