

Lead & Copper Rule Corrosion Control Report

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: Jan - March (Q1) 2021

Required Sample Frequency: 10/quarter

Location	Date	Time	Cl2	Cond	Temp	pH	Alk	yes/no	Has sample met the minimum water quality parameters?		
118	26-Jan	12:48	1.10	33	9.6	8.55					
69	10-Mar	11:50	1.60	29	9.0	8.65					
40	23-Mar	11:53	1.68	36	10.5	9.20					
72	8-Feb	3:09	1.69	34	9.4	8.18					
65	25-Jan	11:47	1.31	32	9.0	8.33					
31	3-Feb	12:01	1.63	27	9.6	8.20					
21	1-Mar	12:43	1.43	35	10.6	8.90					
3	2-Feb	13:00	0.56	34	9.9	8.45					
45	2-Feb	9:02	0.71	67	9.8	8.13					
82	23-Feb	10:48	1.43	27	7.6	8.35					
									Minimum Water Quality Parameters as set by:		
										pH	7.40
										Alk	
										PO4	
										Other	

Total number of excursions during this monitoring period = **0**

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Print Name: William Richmond
 Signature: *William Richmond*
 Date: 04.05.2021