

Lead & Copper Rule Corrosion Control Report

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: April - June (Q2) 2022

Required Sample Frequency: 10/quarter

Location	Date	Time	Cl2	Cond	Temp	pH	Alk	yes/no
118	25-Apr	11:25	1.72	55	11.7	8.39	n/a	yes
69	3-May	13:20	1.65	64	11.8	8.70	n/a	yes
40	23-May	12:00	1.97	66	14.5	8.42	n/a	yes
72	19-Apr	13:37	1.71	34	11.1	8.55	n/a	yes
65	17-May	11:30	1.64	66	11.6	8.50	n/a	yes
31	17-May	13:10	1.52	61	12.1	8.42	n/a	yes
21	17-May	12:00	1.38	70	13.1	8.50	n/a	yes
3	3-May	12:45	1.58	64	12.6	8.32	n/a	yes
45	18-Apr	12:38	0.70	70	11.7	8.02	n/a	yes
82	4-May	12:55	1.57	52.5	10.8	8.59	n/a	yes

< Has sample met the minimum water quality parameters?

Minimum Water Quality Parameters as set by:	
pH	7.40
Alk	
PO4	
Other	

Total number of excursions during this monitoring period = **0**

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Print Name: William Richmond
 Signature: *William Richmond*
 Date: 6.06.22