

Lead & Copper Rule Corrosion Control Report

WATER QUALITY PARAMETER MONITORING - DISTRIBUTION SYSTEM DATA

PWS Name/ID: Tualatin Valley Water District/4100665

Sample Period: Jan - Mar (Q1) 2023

Required Sample Frequency: 10/quarter

Location	Date	Cl2	Cond	Temp	pH	Alk	yes/no	< Has sample met the minimum water quality parameters?
118	17-Jan	1.32	74	10.8	8.31	n/a	yes	
69	6-Feb	1.47	73	9.2	8.84	n/a	yes	
40	17-Jan	1.29	77	10.3	8.93	n/a	yes	
72	14-Feb	1.36	68	8.8	8.82	n/a	yes	
65	10-Jan	1.99	64	10.4	8.50	n/a	yes	
31	21-Feb	2.00	63	8.1	8.92	n/a	yes	
21	27-Feb	1.30	109	6.6	8.04	n/a	yes	
3	7-Feb	1.66	64	8	8.86	n/a	yes	
45	6-Feb	0.90	111	8.7	8.11	n/a	yes	
82	24-Jan	1.52	69	8.6	9.00	n/a	yes	

Minimum Water Quality Parameters as set by:	
pH	7.40
Alk	
PO4	
Other	

total number of excursions during this monitoring period = **0**

Send to dwp.dmce@state.or.us within 10 days after end of sampling period

Print Name: William Richmond
 Signature: *William Richmond*
 Date: 03.03.23